

			Year	
Quality pursuant to the quality standards for network services (QNS)	Time limit for the performance of the operation	Criterion	Total of performed operations	Performance of performed operations (QNS)
<b>Service area of a distribution</b>			times	
Interruption after payment of amounts overdue of the service if interruption of supply electricity network is not required	5 business days	after receipt of payment of the service charge for re-energisation	1137	
Interruption after payment of amounts overdue of the service if interruption of supply electricity network is required	8 business days	after receipt of payment of the service charge for re-energisation		
Resolution of the market participant's point of view in order to resolve metering-related issues	5 business days	after receipt of a request from the market participant	64	
Response to inquiries regarding charges and payments	5 business days	from receipt of inquiry	81,916	
Restoration of the network connection at the request of the market participant if interruption of supply electricity network is not required	5 business days	after receipt of a request from the market participant	98	
Restoration of the network connection at the request of the market participant if interruption of supply electricity network is required	8 business days	after receipt of a request from the market participant		
Provision of a metering device or its replacement and the relevant prices at the request of the market participant	7 business days	after receipt of a request from the market participant	2251	
Notification of a scheduled interruption to the market participant	at least 2 days	before scheduled interruption	350,670	

Response to inquiries regarding charges and payments also includes inquiries regarding meter readings. Inquiries are primarily made via hotline and

**Table 2 Indicators of security of supply and voltage quality**

Anne  
x 2

1.	Interruptions	Time limit			Unit	Year		
		Transmission network	Distribution network			Total	not complying with the QRFNS	complying with the QRFNS
			1 Apr.- 30 Sept.	1 Oct.- 31 Mar.				
1.1	Number of interruptions due to failure caused by force majeure (e.g. natural disaster) QRFNS § 4 (3)	3 days	3 days		pcs	38,534	472	38,062
1.2	Number of interruptions due to failure QRFNS § 4 (4; 5) (except the interruptions listed in clause 1.1.)	12 hours	12 hours	16 hours	pcs	849,302	95,259	754,043
1.3	Number of points of consumption where the total annual duration of interruptions caused by failure exceeded the limit QRFNS § 4 (6)	150 hours	70 hours		pcs		258	
1.4	Number of scheduled interruptions QRFNS § 4 (7)	–	10 hours	8 hours	pcs	331,568	1014	330,554
1.5	Number of points of consumption where the total annual duration of interruptions exceeded the limit QRFNS § 4 (8)	–	64 hours		pcs		1	

without a storm

2.	Indicators of security of supply	Unit	Quantity	
2.1	Total points of consumption	pcs	660,595	
2.2	Total annual duration of interruptions due to failure	minute	121,293,779	
2.3	Total annual duration of scheduled interruptions	minute	49,258,331	
2.4	Average frequency of interruptions due to failure per point of consumption per year QRFNS § 5 (2) (CI) (SAIFI)	pcs	1.84	1.36
2.5	Average duration of interruptions due to failure per point of consumption per year QRFNS § 5 (3) (SAIDI)	minute	184	130
2.6	Average annual duration of interruptions due to failure QRFNS § 5 (4) (CAIDI)	minute	100	96

2.7 .	Average frequency of scheduled interruptions per point of consumption per year	pcs	0.514
2.8 .	Average duration of scheduled interruptions per point of consumption per year	minute	75.00
2.9 .	Average annual duration of scheduled interruptions	minute	146

<b>3.</b>	<b>Voltage quality of the distribution network</b>	<b>Unit</b>	<b>Quantity</b>
3.1 .	Number of connection points where voltage does not correspond to standard EVS-EN 50160:2000 (including a tolerance of $\pm 10\%$ ); QRFNS § 6	pcs	2782